

Fire Test Certificate

Tuesday, 16th October 2018

Supplier: Terra Mater Hardwood Floors Pty Ltd (23-27 Rodeo Drive, Dandenong South, VIC, 3175)

Sample Description: Linwood Misty Grey 3786 Flooring Board

Date Tested: October 2018 (Tested by a Laboratories – NATA Accreditation 1356)

Test Method: AS/ISO 9239-1:2003 Reaction to Fire Tests for Floorings. Determination of the Burning Behaviour using a Radiant Heat Source.

Test results:

AS/ISO 9239-1:2003	Linwood Misty Grey 3786 Flooring Board
Critical Heat Flux/Critical Radiant Flux*	3.6 kW/m ²
HF – 30 Values*	4.3 kW/m ²
Smoke Value*	21 %min
Smouldering	Yes
Blistering	Yes
Glowing	Yes

*Three test average value



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Tuan Duong
BEng (Chemical)
Consultant

CV180899J