

Wet Slip Test Certificate

Tuesday, 16th October 2018

Supplier: Terra Mater Hardwood Floors Pty Ltd (23-27 Rodeo Drive, Dandenong South, VIC, 3175)

Sample Description: Linwood Misty Grey 3786 Flooring Board

Date Tested: September 2018 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: AS/NZS 4586-2013 Appendix B “Slip resistance classification of new pedestrian surface materials – Dry Floor Friction Test Method” using Slider 96

Sample Identification	Wet floor friction result ¹	Classification ² (AS 4586-2013 Australian Standards)
Linwood Misty Grey 3786 Flooring Board	38.4	P3

¹ Five test average value

² The classifications indicate the contribution of the floor surfaces to the risk of slipping when wet is moderate



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Nick Joy
BSc(Hons)
Consultant



Tuan Duong
B. Eng. (Chemical)
Consultant

CV180899J