

Emission Test Certificate

Thursday August 6th, 2009

Supplier: Premium Floors Pty Ltd (67 Quantum Close, Dandenong South Vic 3175)

Sample Description: Readyflor Uniclic Engineered Harwood Flooring

Date Tested: July 2009 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data:

Specification Green Building Council of Australia Green Star Office Design V2 IEQ-13 Green Star Office Design V3 IEQ-13 Green Star Office Interiors V1.1 IEQ-11	Readyflor Uniclic Engineered Hardwood Flooring
Total Volatile Organic Compound emission rate <0.5 mg/m ² /hr (24 hours)	Total Volatile Organic Compound emission rate <0.05 mg/m ² /hr (24 hours)
4-Phenylcyclohexene emission rate <0.05 mg/m ² /hr (24 hours)	4-Phenylcyclohexene emission rate <0.01 mg/m ² /hr (24 hours)



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

CV090725