

# AWTA PRODUCT TESTING

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing  
A.B.N 43 006 014 106  
1st Floor, 191 Racecourse Road, Flemington, Victoria 3031  
P.O Box 240, North Melbourne, Victoria 3051  
Phone (03) 9371 2400

## TEST REPORT

**Client :** Paxwood Pty Ltd T/A Clever Choice Design Floors  
Unit 1  
164 Adderlely Street  
West Auburn NSW 2144

**Test Number :** 20-003090  
**Issue Date :** 6/07/2020  
**Print Date :** 8/07/2020

**Sample Description** Clients Ref : "Clever Hybrid"  
SPC flooring  
Colour : Barcelona  
End Use : Flooring  
Nominal Composition : Stone, Plastic composite  
Nominal Mass per Unit Area/Density : 2100kg/m<sup>3</sup>  
Nominal Thickness : 6mm

### AS 4586-2013 Appendix A

### Slip Resistance Classification of new Pedestrian Surface Materials Wet Pendulum Test Method

Date of Testing 06/07/2020  
Test Temperature (20±5degC) 22 °C  
Sample Preparation Washed with pH neutral detergent and dried.  
Test Direction Length  
Fixed/Unfixed Unfixed  
Slider No 96 Batch No 87  
Length 1 2 3 4 5 SRV  
British Pendulum 42 40 40 40 40 40  
Number  
Classification P3

Equipment: Cooper Pendulum Skid Tester Serial No: 1433-01 Calibrated 08/11/2019  
Slider prepared using P400 and 3µm lapping film.

These results apply only to the specimens tested and it is recommended that before selection of flooring or paving materials the effect of service conditions, including maintenance and wear on their slip resistance be checked.

208163

44914

Page 1 of 1

© Australian Wool Testing Authority Ltd  
Copyright - All Rights Reserved



Accredited for compliance with ISO/IEC 17025 - Testing  
- Chemical Testing : Accreditation No. 983  
- Mechanical Testing : Accreditation No. 985  
- Performance & Approvals Testing : Accreditation No. 1356

Samples and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved by the Managing Director of AWTA Ltd.

APPROVED SIGNATORY



MICHAEL A. JACKSON B.Sc. (Hons)  
MANAGING DIRECTOR