

Wet Slip Test Certificate

Wednesday December 23rd, 2020

Supplier: Australian Select Timbers PTY LTD (136 Atlas Boulevard Dandenong South, VIC, 3175, Australia)

Sample Description: Hickory Impressions

Date Tested: April 2015 (Tested through FORAY Laboratories - NATA Accreditation 1231)

Test Method: AS/NZS 4586-2013 Appendix A "Slip resistance classification of new pedestrian surface materials – Wet Pendulum Test Method" using a Four S slider (Slider 96)

Test Data:


Sample Identification	Slip Resistance Value (SRV) ¹	Classification ² (Classification of Pedestrian Surface materials Accordance to The AS 4586 Wet Pendulum Test)
Hickory Impressions	17	P1

¹ Five test average value

² The classifications indicate that the contribution of the floor surfaces to the risk of slipping when wet is very high.



Dr. Vyt Garnys
PhD, BSc(Hons) AImm, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Srikanth C. Srivatsa
PhD (Chemistry)
Consultant



Tuan Duong
PhD (Chemical Eng.)
Senior Consultant

CV140326 A