

Emission Test Certificate

Thursday, 16th November 2017

Supplier: Australian Select Timbers (61-63 Discovery Road, Dandenong, VIC, 3175)

Sample Description: Regency Hardwood

Date Tested: October 2017 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data (24 hrs):

<p align="center">Green Building Council of Australia</p> <p align="center">Green Star Office Design v3 IEQ-13</p>	<p align="center">Regency Hardwood</p>
<p>Total Volatile Organic Compound Emission Rate limit <0.5 mg/m²/hr</p>	<p>Total Volatile Organic Compound Emission Rate: 0.101 mg/m²/hr</p>
<p>4-phenylcyclohexene Emission Rate Limit: <0.05 mg/m²/hr</p>	<p>4-phenylcyclohexene Emission Rate: <0.005 mg/m²/hr</p>
<p>Formaldehyde Emission Rate limit <0.1 mg/m²/hr</p>	<p>Formaldehyde Emission Rate: 0.009 mg/m²/hr</p>



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Nick Joy
BSc(Hons)
Consultant



Tuan Duong
B Eng. (Chem.)
Consultant

CV171022